

Form 15—Compliance certificate for building design or specification

NOTE: This is to be used for the purposes of section 10 of the *Building Act 1975* and/or section 46 of the *Building Regulation 2006*.

RESTRICTION: A building certifier (class B) can only give a compliance certificate about whether building work complies with the BCA or a provision of the Queensland Development Code (QDC). A building certifier (Class B) can not give a certificate regarding QDC boundary clearance and site cover provisions.

1. Property description

This section need only be completed if details of street address and property description are applicable.

E.g. in the case of (standard/generic) pool design/shell manufacture and/or patio and carport systems this section may not be applicable.

The description must identify all land the subject of the application.

The lot and plan details (e.g. SP/RP) are shown on title documents or a rates notice.

If the plan is not registered by title, provide previous lot and plan details.

Street address (include no., street, suburb/locality and postcode)

Chellikee Street, Kowanyama

Queensland

Postcode 4892

Lot and plan details (attach list if necessary)

Lot 68 on SP272069

In which local government area is the land situated?

Kowanyama Aboriginal Shire Council

2. Description of component/s certified

Clearly describe the extent of work covered by this certificate, e.g. all structural aspects of the steel roof beams.

This certificate covers the certification of the new areas as noted on the referenced documentation only and is based on the surrounding areas being fully compliant.

Emergency Escape Lighting and Exit Signage

Energy Efficiency

Safe Movement

3. Basis of certification

Detail the basis for giving the certificate and the extent to which tests, specifications, rules, standards, codes of practice and other publications, were relied upon.

AS2293.1-2018 Emergency Escape Lighting and Exit for Buildings

AS1680.1 Lighting For Safe Movement

NCC 2019 Section J (Part J6) Energy Efficiency

Aggregate Maximum Illumination Power Density (Budget) = 15.2 W/m²

Aggregate Maximum Illumination Power Density (Spend) = 5.7 W/m² (37%)

<p>4. Reference documentation Clearly identify any relevant documentation, e.g. numbered structural engineering plans.</p>	<table border="1"> <tr><td>2953-E01 (T1) Legend & Notes</td></tr> <tr><td>2953-E02 (T1) Lighting Layout</td></tr> <tr><td>2953-E04 (T1) Single Line Diagram & Details</td></tr> </table>	2953-E01 (T1) Legend & Notes	2953-E02 (T1) Lighting Layout	2953-E04 (T1) Single Line Diagram & Details
2953-E01 (T1) Legend & Notes				
2953-E02 (T1) Lighting Layout				
2953-E04 (T1) Single Line Diagram & Details				
<p>5. Building certifier reference number</p>	<p>Building certifier reference number</p> <input type="text"/>			
<p>6. Competent person details A competent person for building work, means a person who is assessed by the building certifier for the work as competent to practice in an aspect of the building and specification design, of the building work because of the individual's skill, experience and qualifications in the aspect. The competent person must also be registered or licensed under a law applying in the State to practice the aspect.</p> <p>If no relevant law requires the individual to be licensed or registered to be able to give the help, the certifier must assess the individual as having appropriate experience, qualifications or skills to be able to give the help.</p> <p>If the chief executive issues any guidelines for assessing a competent person, the building certifier must use the guidelines when assessing the person.</p>	<p>Name (in full) <input type="text" value="Joe Catalano"/></p> <p>Company name (if applicable) <input type="text" value="SEQUAL Consulting Group Pty Ltd"/> Contact person <input type="text" value="Joe Catalano"/></p> <p>Phone no. (business hours) <input type="text" value="1300 Ask Sequal"/> Mobile no. <input type="text"/> Fax no. <input type="text"/></p> <p>Email address <input type="text" value="joe@consultsequal.com.au"/></p> <p>Postal address <input type="text" value="PO Box 797N"/> <input type="text" value="NORTH CAIRNS"/> Postcode <input type="text" value="4870"/></p> <p>Licence or registration number (if applicable) <input type="text" value="RPEQ No. 05934"/></p>			
<p>7. Signature of competent person This certificate must be signed by the individual assessed by the building certifier as competent.</p>	<p>Signature <input type="text"/></p> <p>Date <input type="text" value="07/08/2020"/></p>			

LOCAL GOVERNMENT USE ONLY

Date received		Reference Number/s	
----------------------	--	---------------------------	--

The *Building Act 1975* is administered by the Department of Housing and Public Works